	Ref. Certif. No.
IEC IECEE CTL	HU-002777

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	surge protector (Surge Protective Device)
Name and address of the applicant	Wenzhou Arrester Electric Co., Ltd. 5th FL, No. 666 Yaming Road, Xiangyang Industry Park, Liushi, Yueqing 325604 Zhejiang, P.R. China
Name and address of the manufacturer	Wenzhou Arrester Electric Co., Ltd. 5th FL, No. 666 Yaming Road, Xiangyang Industry Park, Liushi, Yueqing 325604 Zhejiang, P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Wenzhou Arrester Electric Co., Ltd. 5th FL, No. 666 Yaming Road, Xiangyang Industry Park, Liushi, Yueqing 325604 Zhejiang, P.R. China
Ratings and principal characteristics	Nominal discharge current (In): 20kA; Max. discharge current (Imax): 40kA; Max. impulse current (Iimp): 1) 7kA (L-N/PE), 12.5kA (N-PE); 2) N/A; Max. continuous operation voltage (Uc): AC 75V (L-N/PE), AC 255V (N-PE); Voltage protect level(Up): 0.75kV (L-N/PE), 1.5kV (N-PE); Modes of protection: L-N, N-PE or L-PE, N-PE; Type of SPD: 1) Type 1 + Type 2, 2) Type 2; IP code: IP20; short-circuit current rating(Isccr): 25kA (see Test Report for further ratings)
Trademark (if any)	LSP
Customer's Testing Facility (CTF) Stage used	---
Model / Type Ref.	1) FLP7-75/1+1, FLP7-75/1S+1, FLP7-75/1, FLP7-75/1S, FLP7-75/2, FLP7-75/2S; 2) SLP40-75/1+1, SLP40-75/1S+1, SLP40-75/1, SLP40-75/1S, SLP40-75/2, SLP40-75/2S
Additional linformation (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	19081622G

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., Division ME
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

TÜV Rheinland LGA Products GmbH Zertifizierungsstelle

Date: 2019-11-25

Signature: Gabor Kassai